



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

kcmo.gov/planning

September 18, 2024

Kaitlin Raynor
Kimley Horn
805 Pennsylvania Ave Suite 150, STE 150
Kansas City, MO 64105

Re: **CLD-FnPlat-2024-00019** - A request to approve a Final Plat in District MPD (Master Planned Development) on about 20 acres generally located north of Northwest 96th Street along North Robinhood Avenue, allowing for the creation of 63 residential lots and 3 tracts.

Dear Kaitlin Raynor:

At its meeting on September 18, 2024, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is only a recommendation. Your request must receive final action from the . All conditions imposed by the Commission, if any, are available on the following page(s).

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for final consideration.

If you have any questions, please contact me at matthew.barnes@kcmo.org or (816) 513-8817.

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew Barnes".

Matthew Barnes
Lead Planner

Condition(s) by City Planning and Development Department. Contact Matthew Barnes at (816) 513-8817 / matthew.barnes@kcmo.org with questions.

1. That prior to submitting documents for the final approval of conditions the applicant ensure that the Title Report is current within 90 days or submit an updated Title Report.
2. That prior to issuance of the Certificate of Occupancy for the first house built the developer must post a sign at the terminus of all stub streets indicating that the stub street is intended to be opened to through traffic when the adjacent property is developed. The sign must state "FUTURE THROUGH STREET. TO BE CONNECTED WHEN ABUTTING PROPERTY DEVELOPS."
3. That prior to submitting documents for final approval the applicant upload Paid Tax Receipts for the most recent applicable year.
4. That prior to submitting documents for the final approval of conditions the applicant update the plat to reflect the correct City Plan Commission Date, Ordinance Number, and Council Approval Date by utilizing the Official City Signature Block found under Table 7 in the Directors Minimal Submittal Requirements and insert Case No. CLD-FnPlat-2024-00019.
5. That prior to recording the Final Plat the developer shall upload and secure approval of a Street Tree Planting Plan from the City Forester.
6. That prior to issuance of the Certificate of Occupancy for each lot within the plat the developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved Street Tree Planting Plan and are healthy.
7. That prior to recording of the Final Plat the applicant must obtain approval of an MPD Final Plan for Woodhaven 2nd Plat under Case CD-CPC-2024-00091.
8. That prior to recording of the Final Plat the applicant must include details of Tract 2B for the Clubhouse and Pool under the MPD Final Plan (CD-CPC-2024-00091), submit a separate MPD Final Plan for Tract 2B, or amend the preliminary plat to show Tract 2B as a part of the 3rd plat and provide details of the tract during the next MPD final plan.
9. That applicant shall receive approval through a separate MPD Final Plan for all private open space and amenities in Tract 2B. The MPD final plan for Tract 2B may be submitted concurrently with final construction drawings but must be approved prior to issuance of the permit.
10. That prior to recording of the Final Plat the following Plat review corrections must be corrected: 1. Tract 2A planned for use as stormwater detention will require a Covenant to Maintain Storm Water Detention Facility agreement. Add a separate maintenance of tract paragraph having the following language: "MAINTENANCE OF TRACT: Tract (___) is to be used for (state use) and shall be maintained by the owners of the lots, tracts, and parcels shown within this plat pursuant to the (name of document) recorded simultaneously with this plat. 2. Please verify if Private Open Space is being reserved related to parkland dedication.
11. That prior to recording of the Final Plat the following Plat review corrections must be resolved: 1. The Maintenance of Tract paragraph for Tract 2A should reference the "Covenant to Maintain Storm Water Detention Facility Plat of Woodhaven - 2nd Plat" agreement.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

12. Required fire department access roads shall be a minimum unobstructed width of twenty (20) feet and 13 ft. 6 in clearance height. Check with Streets & Traffic (KCMO Public Works) or Missouri Department of Transportation (MODOT) that may have street planning regulations that supersede the Fire Code. (IFC-2018: § 503.2.1)
A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3)
Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5)
Required fire department access roads shall designed to support a fire apparatus with gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3)
Shall provide fire lane signage on fire access drives.
The turning radius for fire department access roads shall be 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4)

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

13. One and two family residential developments exceeding 30 dwelling units shall have at least two separate and approved fire apparatus access roads (IFC-2018: § D107.1)
Where two fire apparatus access roads are required, they shall be placed a distance apart equal to not less than one half of the length of the maximum overall diagonal dimension of the lot or area to be served, measured in a straight line between accesses. (IFC-2018: § D106.3)
14. The developer shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1)
15. Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
Fire hydrant distribution shall follow IFC-2018 Table C102.1

Condition(s) by Parks & Recreation. Contact Richard Sanchez at / richard.sanchez@kcmo.org with questions.

16. The developer shall submit a streetscape plan with street tree planting plan per 88-425-03 for approval and permitting by the Parks & Recreation Department's Forestry Division prior to beginning work in the public right-of-way
17. The developer shall be responsible for dedication of parkland, private open space in lieu of parkland, or payment of cash-in-lieu of either form of dedication, or any combination thereof in accordance with 88-408. Should the developer choose to pay cash-in-lieu of dedicating all or a portion of the required area, the amount due shall be based upon the 2021 acquisition rate of \$48,801.37 per acre. This requirement shall be satisfied prior to recording of the final plat.

Condition(s) by Public Works Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

18. The developer shall submit construction plans in compliance with adopted standards for all improvements required by the traffic study approved by the Public Works Department, and shall secure permits for those improvements as required by the Land Development Division, prior to recording the plat.
19. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
20. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, provide a copy of the Storm Water Pollution Prevention (SWPP) plan submitted to the Missouri Dept. of Natural Resources (MDNR) and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
21. The developer must design and construct all interior public streets to City Standards, as required by Chapter 88 and the Land Development Division, including curb and gutter, storm sewers, street lights, and sidewalks.
22. The developer shall submit covenants, conditions and restrictions to the Land Development Division for review by the Law Department for approval for the maintenance of private open space and enter into a covenant agreement for the maintenance of any stormwater detention area tracts, prior to recording the plat.
23. The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.
24. The developer shall cause the area to be platted and processed in accordance with Chapter 88, Code of Ordinances of the City of Kansas City, Missouri.

Condition(s) by Water Services Department. Contact Kirk Rome at (816) 513-0368 / kirk.rome@kcmo.org with questions.

25. Show and label all water main easements on the plat based on final approved water main extension plans.