



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

September 19, 2023

Robin W Polk  
Cook, Flatt & Strobel Engineers, P.A.  
1421 E 104th St  
Kansas City, MO 64131

Re: **CD-CPC-2023-00137** - A request to approve a project plan for the construction of an eating and drinking establishing and drive-through facility in district B3-2 on about .56 acres generally located at Westport Road and State Line Road.

Dear Robin W Polk:

At its meeting on September 19, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is final. All conditions imposed by the Commission, if any, are available on the following page(s).

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at [Andrew.Clarke@kcmo.org](mailto:Andrew.Clarke@kcmo.org) or (816) 513-8821

Sincerely,

A handwritten signature in black ink that reads "Andrew Clarke".

Andrew Clarke  
Planner



## Plan Conditions

Report Date: September 14, 2023

Case Number: CD-CPC-2023-00137

Project: Chipotle on Westport Road

---

*Condition(s) by City Planning and Development Department. Contact Andrew Clarke at (816) 513-8821 / [Andrew.Clarke@kcmo.org](mailto:Andrew.Clarke@kcmo.org) with questions.*

1. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
3. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
4. All signage shall conform to 88-445 and shall require a sign permit prior to installation.
5. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / [Terry.A.Thomas@kcmo.org](mailto:Terry.A.Thomas@kcmo.org) with questions.*

6. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
7. The developer shall submit a streetscape plan for approval and permitting by the Land Development Division prior to beginning construction of the streetscape improvements in the public right of way, and construct ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired.
8. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the disturbed area to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted prior to issuance of any building permits, and the developer secure permits to construct any improvements required by the Land Development Division prior to issuance of any certificate of occupancy.
9. The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.
10. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
11. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

12. • The project shall meet the fire flow requirements as set forth in Appendix B of the International Fire Code 2018. (IFC-2018 § 507.1)
13. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
  - Fire hydrant distribution shall follow IFC-2018 Table C102.1

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.*

14. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.  
South of River contact - Sean Allen - 816-513-0318  
North of River contact - Pedro Colato 816-513-4892

15. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.

<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>

*Condition(s) by Water Services Department. Contact Lucas Kaspar at (816) 513-2131 / Lucas.Kaspar@kcmo.org with questions.*

16. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the disturbed area to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted prior to issuance of any building permits, and the developer secure permits to construct any improvements required by the Land Development Division prior to issuance of any certificate of occupancy.