



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

KCMO.gov/Planning

June 22, 2026

Charles Renner
Husch Blackwell
4801 Main St
Kansas City, MO 64112

Re: **CD-CPC-2026-00044** - A request to approve a development plan for an entertainment venue in district B4-5 on about 2.2 acres generally located south of E 49th Street between Main Street and Walnut Street.

Dear Charles Renner:

At its meeting on June 17, 2026, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is only a recommendation. Your request must receive final action from the Council. All conditions imposed by the Commission, if any, are available on the following page(s).

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for Council consideration.

If you have any questions, please contact me at genevieve.kohn-smith@kcmo.org or (816) 513-8808.

Sincerely,

A handwritten signature in cursive script that reads "Genevieve Kohn-Smith".

Genevieve Kohn-Smith, AICP
Lead Planner

That plans, revised as noted below, are submitted and accepted by staff prior to scheduling for Council.

The following are recommended by the Development Management Department. For questions, contact Genevieve Kohn-Smith at genevieve.kohn-smith@kcmo.org or (816) 513-8808.

- 1) Does the photometric lighting plan include existing street lighting? The spillover light on the plan as submitted exceeds the 1 footcandle permitted into the public ROW and 0.186 onto R zoned property to the south.
ong Range Planning:
provide a way to dim the lights on the east and south sides of the proposed building to prevent a nuisance for adjacent residents.
2. provide a time limit (auto switch?) for the lights on the east and south sides of the building to prevent a nuisance for adjacent residents.
3. perhaps cap the lighting at the top of the lighting structures on the building so they do not shine upward into the night sky.

UPDATE 6/4/26: The photometric plan is still not clear on what amount of spillover light will be produced by the proposed lights on the building along Walnut St. Provide any notes on the plan ensuring spillover light from the building will not exceed 0.186 foot-candle onto R-zoned property and 1.0 foot-candle onto public rights-of-way. Revise Plans and Resubmit

Condition(s) by City Planning and Development Department. Contact Genevieve Kohn-Smith at (816) 513-8808 / genevieve.kohn-smith@kcmo.org with questions.

1. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with Section 88-425-08 of the Zoning and Development Code. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
3. All signage shall conform to Section 88-445 and shall require a sign permit prior to installation. This condition may be satisfied by an assigned City Planning and Development Department Building Inspector.
4. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
5. That prior to issuance of the Certificate of Occupancy for each lot within the plat the developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved Street Tree Planting Plan and are healthy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
6. Resolve outstanding corrections prior to request for ordinance.
7. The applicant shall consider activating the building during regular business hours with an additional commercial tenant.
8. The applicant shall work with staff to ensure adequate egress, primarily for areas with the highest amounts of pedestrian traffic and towards the streetcar, including but not limited to sidewalk improvements, prior to Council approval.

Condition(s) by City Planning and Development Department. Contact Matthew Barnes at (816) 513-8817 / matthew.barnes@kcmo.org with questions.

9. That prior to issuance of the Certificate of Occupancy, the applicant must consolidate the lots through a City Approved process.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

10. The turning radius for fire department access roads shall be 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4)
11. Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
12. The developer shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1)
13. All Fire Department Connections (FDC) shall be threaded connections, Storz connections are not allowed in the City of Kansas City, Missouri (IFC-2018 § 903.3.6; NFPA 13-2010 § 6.8.1).
14. Fire hydrant(s) shall be within 400 feet on a fire access road following an approved route established by the Authority Having Jurisdiction (AHJ) of any exterior portion of a building. The use of existing fire hydrant(s) may be used to satisfy this requirement otherwise a private fire hydrant(s) or hydrant system may be required. This distance may be increased to 600 feet for R-3 and U occupancy(s) or the building(s) is fully protected by an approved automatic fire sprinkler system(s). (IFC-2018: § 507.5.1)
15. The building's FDC shall be immediately recognizable from the street or nearest point of Fire Department access (IFC-2018 § 912.2.1).
16. The Fire Department Connection (FDC) shall not be located that obstructs access/egress to the building when in use (IFC-2018 § 912.2).

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

17. New buildings shall have approved radio coverage for emergency responders within the building based on the existing coverage levels of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. This section shall not require improvement of the existing public safety communication systems. (IFC 2018 510.1) and (NFPA1221)
18. Fire hydrant distribution shall follow IFC-2018 Table C102.1
19. A Knox Box shall be provided near the main entrance to the building (IFC-2018 § 506.1). To ensure proper keying to Kansas City, Missouri; Knox Boxes may be ordered online at www.knoxbox.com or on an official order form obtained through this Office.
20. Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1)
21. The developer shall provide fire lane signage on fire access drives.

Condition(s) by Public Works Department. Contact Jeffrey Bryan at (816) 513-6991 / Jeffrey.Bryan@kcmo.org with questions.

22. Prior to certificate of occupancy the owner shall submit to the Public Works Department City Traffic Engineer the event management plan. The owner shall also submit for review to Public Works Permitting prior to each event the traffic control plans, any permit applications, and other event information needed for the given event.
23. The applicant shall work with Public Works regarding cost sharing opportunities related to the Ward Parkway two-way conversion in the project area, prior to building permit.

Condition(s) by Public Works Department. Contact Nicolas Bosonetto at (816) 513-2746 / nicolas.bosonetto@kcmo.org with questions.

24. Applicant shall formulate event traffic management plans as described in the TIS. These management plans shall describe all efforts to be carried out by applicant prior to, during, and following an event to assure safety and efficiency of traffic and parking operations related to the event. This plan shall be submitted to PW for review and approval. The applicant shall be responsible for assuring all measures in the event traffic management plans are carried out as a condition of approval.

Condition(s) by Public Works Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

25. The developer shall integrate into the existing street light system any relocated existing street lights within the street right-of-way impacted by the new drive or approach entrances as required by the Land Development Division, and the relocated lights must comply with all adopted lighting standards.
26. The developer shall submit a streetscape plan for approval and permitting by the Land Development Division prior to beginning construction of the streetscape improvements in the public right of way, and construct ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired.
27. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
28. The developer shall pay the arterial street impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.

Condition(s) by Public Works Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

29. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
30. Owner/developer shall enter into a covenant agreement for the perpetual maintenance of all nonstandard construction items (brick pavers, landscaping etc.) located within the public right-of-way. Agreement shall be executed and recorded prior to the issuance of any certificate of occupancy.
31. Applicant shall obtain approval by the Transportation Development Committee (TDC) for the requested non-compliant driveway width(s) prior to City Council approval.

Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.

32. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.
South of River contact - Patrick Lewis (816) 513-0423
North of River contact - David Gilyard (816) 513-4772
33. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to issuance of Certificate of Occupancy.
<https://www.kcwater.us/wp-content/uploads/2025/02/2025-Final-Rules-and-Regulations-for-Water-Service-Lines.pdf>

Condition(s) by Water Services Department. Contact Kirk Rome at (816) 513-0368 / kirk.rome@kcmo.org with questions.

34. The developer shall submit water main extension plans prepared by a Missouri PE through CompassKC for review, acceptance and contracts for a minimum of one additional public fire hydrant along 49th Street. The plans shall follow KC Water Rules and Regulations for Water main extensions and Relocations. The plans shall be under contract (permit) prior to final plat recording or building permit issuance whichever occurs first. Additional information is available online at:
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Main-Extensions-Final2.pdf>

Condition(s) by Water Services Department. Contact Philip Taylor at (816) 513-0146 / philip.taylor@kcmo.org with questions.

35. The developer shall secure permits to extend public sanitary and storm water conveyance systems to serve all proposed lots within the development and determine adequacy of receiving systems as required by KC Water, prior to recording the plat or issuance of a building permit whichever occurs first.
36. The developer shall obtain the executed and recorded City approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting.
37. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the entire site to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system and manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted, and the developer shall secure permits to construct any improvements required by the Land Development Division prior to recording the plat.
38. The developer shall grant a [BMP and/or Surface Drainage Easement] to the City as required by KC Water, prior to recording the plat or issuance of any building permits.

June 22, 2026

Condition(s) by Water Services Department. Contact Philip Taylor at (816) 513-0146 / philip.taylor@kcmo.org with questions.

39. The developer shall submit plans for grading, siltation, and erosion control to KC Water for review and acceptance, provide a copy of the Storm Water Pollution Prevention (SWPP) plan submitted to the Missouri Dept. of Natural Resources (MDNR) and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
40. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by KC Water prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements may be required.