



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

November 17, 2022

Henry C Klover  
Klover Architects, Incorporated  
8813 Penrose Ln, 400  
Lenexa, KS 66219

Re: **CD-CPC-2022-00173** - A request to approve a Residential Development Plan in district B3-2 for a 4-story apartment building consisting of approximately 220 units above a 2-level parking garage with two courtyards above the podium deck with amenities and a pool, and approximately 6,500 square feet of retail, office, and restaurant space on the ground level on about 3.63 acres generally located at 1500 Meadow Lake Parkway

Dear Henry C Klover:

At its meeting on November 15, 2022, the City Plan Commission acted as follows on the above-referenced case.

Scheduled

*The Commission's action is only a recommendation.* Your request must receive final action from the City Council. All *conditions imposed by the Commission*, if any, *are available on the following page(s)*.

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for City Council consideration.

If you have any questions, please contact me at [Larisa.Chambi@kcmo.org](mailto:Larisa.Chambi@kcmo.org) or (816)513-8822.

Sincerely,

A handwritten signature in cursive script that reads "Larisa Chambi".

Larisa Chambi  
Lead Planner



## Plan Conditions

Report Date: November 17, 2022

Case Number: CD-CPC-2022-00173

Project: 1500 Meadow Lake

---

*Condition(s) by City Planning and Development Department. Contact Larisa Chambi at (816)513-8822 / Larisa.Chambi@kcmo.org with questions.*

1. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
2. That the developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
3. Signage has not been reviewed with this submittal, all signage shall conform to 88-445 and shall require a sign permit prior to installation.
4. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at / Terry.A.Thomas@kcmo.org with questions.*

5. The developer must integrate into the existing street light system any relocated existing street lights within the street right-of-way impacted by the new drive or approach entrances as required by the Land Development Division, and the relocated lights must comply with all adopted lighting standards.
6. The developer must obtain the executed and recorded city approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting
7. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements may be required.
8. The developer must petition for the vacation of sanitary sewer easement as shown on the development plan and relocate sewers as required by the Departments of Water Services, the Land Development Division, and Development Services prior to recording of the final plat.
9. The developer shall submit construction plans in compliance with adopted standards for all improvements required by the traffic study approved by the Public Works Department, and shall secure permits for those improvements as required by the Land Development Division, prior to recording the plat.
10. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
11. The developer shall submit plans to Land Development Division and obtain permits to construct sidewalks along the platted frontage, and to a tie-in point with the existing sidewalks and construct associated ADA ramps at the proposed entrance drives as necessary for the type of drive approach.
12. The developer provide acceptable easement and secure permits to relocated sanitary sewers out from under proposed buildings and structures, etc., while continuing to ensure individual service is provided to all proposed lots as required by Land Development Division prior to recording the plat or issuance of a building permit, whichever occurs first.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at / Terry.A.Thomas@kcmo.org with questions.*

13. Please note that any proposed on-street parking shall be approved by the Public Works Department prior to the issuance of a permit from Land Development for construction. Requests for on-street parking require review by Public Works staff during the plan review process.
14. The developer shall cause the area to be platted and processed in accordance with Chapter 88, Code of Ordinances of the City of Kansas City, Missouri, as amended, commonly known as the Development Regulations.
15. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
16. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the entire site to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted, and the developer shall secure permits to construct any improvements required by the Land Development Division prior to recording the plat.
17. The owner/developer must submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

18. The project shall meet the fire flow requirements as set forth in Appendix B of the International Fire Code 2018. (IFC-2018 § 507.1)
19. New buildings shall have approved radio coverage for emergency responders within the building based on the existing coverage levels of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. This section shall not require improvement of the existing public safety communication systems. (IFC 2018 510.1) and (NFPA1221)
20. Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1)
21. Fire hydrant distribution shall follow IFC-2018 Table C102.1  
  
Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA -2013 § 8.7.2)
22. A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3) Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5) The required fire department access roads shall designed to support a fire apparatus with gross axle weight of 85,000 pounds (IFC-2018: § 503.2.3) and shall provide fire lane signage on fire access drives.
23. Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).
24. Dead end fire department access road(s) in excess of 150 feet shall be provided with an approved turn around feature (i.e., cul-de-sac, hammerhead). Dead-end streets in excess of 150 feet in length resulting from a "phased" project shall provide an approved temporary turn around feature (i.e., cul-de-sac, hammerhead). (IFC-2018: § 503.2.5)

*Condition(s) by Parks & Recreation. Contact Justin Peterson at (816) 513-7599 / Justin.Peterson@kcmo.org with questions.*

*Condition(s) by Parks & Recreation. Contact Justin Peterson at (816) 513-7599 / Justin.Peterson@kcmo.org with questions.*

25. The developer is responsible for dedication of parkland, private open space in lieu of parkland, or payment of cash-in-lieu of either form of dedication, or any combination thereof in accordance with 88-408. Should the developer choose to pay cash-in-lieu of dedicating all or a portion of the required area, the amount due shall be based upon the (2022) acquisition rate of (\$64,220.18) per acre. This requirement shall be satisfied prior to certificate of occupancy.
26. The developer shall submit a streetscape plan with street tree planting plan per 88-425-03 for approval by the Parks & Recreation Department's Forestry Division prior to beginning work in the public right-of-way

*Condition(s) by Public Works Department. Contact Jeffrey Bryan at (816) 513-9865 / Jeffrey.Bryan@kcmo.org with questions.*

27. Please send plans to Monica Kearney at Monica.Kearney@kcmo.org for review of the proposed on-street parking shown on 76th Street.

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.*

28. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.  
South of River contact – Sean Allen - 816-513-0318  
North of River contact Pedro Colato – 816-513-4892
29. Branch service lines one-and-one-half inches and larger in diameter for domestic water services or fire protection lines shall be connected to the main by cutting in a minimum 6" branch service tee, installing three gate valves, and two solid sleeves on the main. Line valves on the main shall be the same nominal size as the main.
30. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.  
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>